

OR

DENOTES TERMINAL BLOCK

SUPER SYSTEMS INC.  
(800) 666-4330  
www.supersystems.com

- 1 - 24VDC (COM)
- 2 - 24VDC (+)
- 3 - RS485 RT (-)
- 4 - RS485 RT (+)
- 5 - SLAVE 1, RS485 (+)
- 6 - SLAVE 1, RS485 (-)
- 7 - RELAY COMMON
- 8 - RELAY OUT 1
- 9 - RELAY OUT 2
- 10 - RELAY OUT 3
- 11 - RELAY OUT 4
- 12 - RELAY OUT 5
- 13 - RELAY OUT 6
- 14 - RELAY OUT 7
- 15 - RELAY OUT 8 NC
- 16 - RELAY OUT 8 NO
- 17 - DIGITAL IN 1
- 18 - ANALOG IN 3 (+)
- 19 - ANALOG IN 3 (-)
- 20 - ANALOG IN 4
- 21 - DIGITAL IN COM
- 22 - SLAVE 2, RS485 (+)
- 23 - SLAVE 2, RS485 (-)
- 24 - 4-20mA OUT 1 (+)
- 25 - 4-20mA OUT 2 (+)
- 26 - 4-20mA OUT 2 (-)
- 27 - ANALOG IN 2 (+)
- 28 - ANALOG IN 2 (-)
- 29 - ANALOG IN 1 (+)
- 30 - ANALOG IN 1 (-)
- 31 - ANALOG IN 1 (+)
- 32 - ANALOG IN 1 (-)

SERIES 9120 PINDOUT LABEL

COMBO ALARM

PROGRAM ALARM, ALARM 01,  
ALARM 02, AND ALARM 03

REFERENCE DRAWING(S)

THIS DRAWING IS FURNISHED AS A  
GUIDELINE ONLY.  
FINAL INSTALLATION DIAGRAMS  
ARE THE RESPONSIBILITY OF OTHERS.

CONFIDENTIAL

REV.	DESCRIPTION	DRAWN	DATE	APPROVED
A	ECD - 00412		24 MAR 2017	

  

APPROVALS	DATE	DWG. NO.	REV.
DRAWN	26 MAR 2014	13560	A
CHECKED	DATE CHKD	ELECTRONICS\13560\	
ISSUED	DATE ISSUED	SCALE	1:1
SHEET 01 OF 02			

  

SERIES 9120 ATMOSPHERE CONTROL SYSTEM - RS-232 COMMUNICATIONS TO 5.7" DIT BASIC WIRING DIAGRAM	
--	--

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
FRACTIONS DECIMALS  
#1/64"

ANGLES  
X, XX=±0.100 ±0.5°  
X, XXX=±0.010 ±0.01°

DR USE OF THIS DRAWING OR THE INFORMATION AND  
SPECIFICATIONS HEREIN IS STRICTLY PROHIBITED.

SSi  
CINCINNATI, OHIO

COMMS TO  
DPVT-123  
PORT 'A'  
(RS-232)

139  
1002 WHT

139  
1001 RED

1002 WHT

